

Moorestown North Church Street Water Treatment Plant

Trichloroethene (TCE) Results

#7 WELL & TP003013	DATE	WELL RESULT	POE RESULT
	Nov. 21, 2012	0.520 ug/l	0.190 Jug/l
	Jan. 2013	0.730 ug/l	0.370 ug/l
	Nov. 2013	1.070 ug/l	0.590 ug/l
	June 23, 2015	1.49 ug/l	See below
	Aug. 26, 2015	2.43 ug/l	See below
	Nov. 18, 2015	2.28 ug/l	See below
	Feb. 3, 2016	2.14 ug./l	See below
#9 WELL & TP003013	May 30, 2012	0.730 ug/l	0.390 Jug/l
	Jul. 25, 2012	0.650 ug/l	0.360 Jug/l
	Oct. 17, 2012	0.860 ug/l	0.460 Jug/l
	June 2013	0.830 ug/l	0.360 Jug/l
	Aug. 2013	0.870 ug/l	0.430 Jug/l
	Feb. 2014	1.16 ug/l	0.590 ug/l
	April 2014	1.49 ug/l	0.720 ug/l
	June 2014	1.55 ug/l	0.710 ug/l
	Aug. 2014	1.53 ug/l	0.710 ug/l
POE – TP003013	Jan. 17, 2008	N/A	0.250 ug/l
	Apr. 13, 2011	N/A	0.300 Jug/l
	June 23, 2015	See above	0.820 ug/l
	Aug. 26, 2015	See above	1.12 ug/l
	Nov. 18, 2015	See above	1.10 ug/l
	Feb. 3, 2016	See above	1.23 ug./l

10/6/2014 – Turned North Church Street plant off at DEP recommendation.

6/17/2015 – Turned North Church Street plant back ON. To resume sampling.

2/18/2016 – Turned North Church Street plant OFF as per Mananger/Council.

Discharge from metal degreasing sites and other factories. MCL 1 ug/l